

Environmental Protection Licence EPL 1730

Yass Valley Council, PO Box 6, Yass, NSW 2582

Yass Sewage Treatment Plant, Faulder Avenue, YASS, NSW 2582

Link to Public Register: <https://www.epa.nsw.gov.au/licensing-and-regulation/public-registers/about-prpoeo>

Yass Sewage Treatment Plant Effluent Quality Data since 2012

EPA Sampling Point: 10 (refer site map for Location)			Monitoring Frequency : Monthly								Comment
Date Sampled	Date Results Obtained	Date Results Published	Pollutant								
			Ammonia (as N) mg/L	BOD ₅ mg/L	Faecal Coliform CFU/100mL	pH	Suspended Solids mg/L	Total Oil & Grease mg/L	Total Phosphorus (as P) mg/L	Total Nitrogen (as N) mg/L	
Limit: 2	Limit: 10	Limit: 200	Limit: 6.5-8.5	Limit: 15	Limit: 2	Limit: 0.3	Limit:10				
12.01.12	29.05.12	29.05.12	0.9	3	6	7.5	6	<1	0.23	4.1	
08.02.12	29.05.12	29.05.12	0.6	5	78	7.6	7	<1	0.24	4.1	
07.03.12	29.05.12	29.05.12	0.5	6	9	7.5	15	<1	0.36	6.1	High inflow due to rain
05.04.12	29.05.12	29.05.12	1	10	17	7.6	3	<1	0.12	4.1	
09.05.12	29.05.12	29.05.12	0.5	<2	8	7.7	4	<1	0.14	5.1	
13.06.12	21.06.12	21.06.12	0.6	3	2	7.7	3	<1	0.13	3.6	
12.07.12	19.07.12	19.07.12	0.4	<2	1	7.6	3	<1	0.10	2.7	
15.08.12	23.08.12	23.08.12	0.2	3	1	7.7	6	<1	0.14	3.3	
04.09.12	11.09.12	11.09.12	0.3	4	<1	7.5	7	<1	0.20	3.7	
04.10.12	12.10.12	15.10.12	0.3	2	1	7.5	11	<1	0.14	3.5	
07.11.12	15.11.12	16.11.12	0.7	6	4	7.3	17	<1	0.28	3.7	
11.12.12	18.12.12	18.12.12	0.5	<2	<1	7.8	6	<1	0.08	3.9	
17.01.13	24.01.13	24.01.13	0.6	<2	110	7.7	10	<1	0.18	3.8	
14.02.13	21.02.13	21.02.13	0.4	<2	23	7.8	6	<1	0.08	2.8	
20.03.13	26.03.13	26.03.13	0.3	2	72	7.9	6	<1	0.09	5	
17.04.13	26.04.13	29.04.13	0.3	3	5	7.7	6	<1	0.10	4.6	
15.05.13	22.05.13	22.05.13	0.4	2	6	7.9	7	<1	0.2	4.6	
13.06.13	21.06.13	21.06.13	0.4	<2	2	7.5	8	<1	0.14	4	
11.07.13	17.07.13	17.07.13	0.3	3	<1	7.7	10	<1	0.18	4.3	
07.08.13	14.08.13	14.08.13	0.4	<2	2	7.5	8	<1	0.16	5.6	
11.09.13	18.09.13	18.09.13	0.4	<2	<1	7.6	8	<1	0.06	3.4	
10.10.13	21.10.13	22.10.13	0.4	3	2	7.6	9	<1	0.14	4.7	
13.11.13	22.11.13	25.11.13	0.4	5	61	7.2	11	<1	0.20	3.7	
18.12.13	02.01.14	06.01.14	0.5	3	14	7.56	8	<1	0.18	3.06	
22.01.14	03.02.14	03.02.14	0.5	3	340	7.9	8	<1	0.37	5.04	Some UV lamps defective, High summer temperature

Environmental Protection Licence EPL 1730

Yass Valley Council, PO Box 6, Yass, NSW 2582

Yass Sewage Treatment Plant, Faulder Avenue, YASS, NSW 2582

Link to Public Register: <https://www.epa.nsw.gov.au/licensing-and-regulation/public-registers/about-prpoeo>

Yass Sewage Treatment Plant Effluent Quality Data since 2012

EPA Sampling Point: 10 (refer site map for Location)			Monitoring Frequency : Monthly								Comment
Date Sampled	Date Results Obtained	Date Results Published	Pollutant								
			Ammonia (as N) mg/L Limit: 2	BOD ₅ mg/L Limit: 10	Faecal Coliform CFU/100mL Limit: 200	pH Limit: 6.5-8.5	Suspended Solids mg/L Limit: 15	Total Oil & Grease mg/L Limit: 2	Total Phosphorus (as P) mg/L Limit: 0.3	Total Nitrogen (as N) mg/L Limit:10	
27.02.14	06.03.14	06.03.14	0.3	<2	55	7.84	5	<1	0.11	3.92	
19.03.14	27.03.14	27.03.14	0.5	<2	82	7.77	6	<1	0.07	4.15	
10.04.14	22.04.14	22.04.14	0.4	3	720	7.56	6	<1	0.1	4.37	Dead Turtle in UV Chamber
08.05.14	19.05.14	20.05.14	0.6	<2	620	7.49	7	<1	0.13	4.41	
26.06.14	07.07.14	08.07.14	0.5	<2	3680	7.43	6	<1	0.04	4.54	High Faecal Coliform results being investigated
17.07.14	24.07.14	24.07.14	0.3	<2	<2	7.39	8	<1	0.1	2.81	
07.08.14	15.08.14	18.08.14	0.4	<2	4	7.56	12	<1	0.25	4.44	
11.09.14	18.09.14	19.09.14	0.4	4	<1	7.33	12	<1	0.20	2.21	
16.10.14	28.10.14	29.10.14	0.7	3	<1	7.43	6	<1	0.08	2.90	
20.11.14	01.12.14	01.12.14	0.8	2	<2	7.62	6	<1	0.17	5.14	
11.12.14	22.12.14	23.12.14	0.7	<2	13	7.74	83	<1	0.08	3.4	
15.01.15	22.01.15	23.01.15	0.5	<2	10	7.72	5	<1	0.08	3.47	
12.02.15	20.02.15	23.02.15	0.8	<2	<2	7.53	8	<1	0.15	3.72	
12.03.15	24.03.15	24.03.15	0.4	3	68	7.68	9	<1	0.17	3.48	
16.04.15	28.04.15	28.04.15	0.3	<2	<2	7.67	6	<1	0.17	4.69	
14.05.15	26.05.15	26.05.15	0.5	<2	<1	7.98	9	<1	0.18	4.51	
25.06.15	08.07.15	10.07.15	0.9	4	2	7.82	12	<1	0.19	3.44	
16.07.15	24.07.15	27.07.15	0.5	<2	<1	7.54	13	<1	0.21	8.08	
13.08.15	24.08.15	25.08.15	0.6	<2	1	7.54	12	<1	0.22	8.89	
30.09.15	13.10.15	14.10.15	23.8	5	<2	7.86	14	<1	0.27	27.7	Cause of high ammonia and nitrogen being investigated
15.10.15	23.10.15	26.10.15	1.7	2	<2	7.79	12	<1	0.20	3.46	
11.11.15	18.11.15	20.11.15	0.9	3	<1	7.77	13	<1	0.29	2.83	
02.12.15	08.12.15	09.12.15	0.7	2	3	7.69	8	<1	0.18	3.09	

Environmental Protection Licence EPL 1730

Yass Valley Council, PO Box 6, Yass, NSW 2582

Yass Sewage Treatment Plant, Faulder Avenue, YASS, NSW 2582

Link to Public Register: <https://www.epa.nsw.gov.au/licensing-and-regulation/public-registers/about-prpoeo>

Yass Sewage Treatment Plant Effluent Quality Data since 2012

EPA Sampling Point: 10 (refer site map for Location)							Monitoring Frequency : Monthly				
Date Sampled	Date Results Obtained	Date Results Published	Pollutant								Comment
			Ammonia (as N) mg/L	BOD ₅ mg/L	Faecal Coliform CFU/100mL	pH	Suspended Solids mg/L	Total Oil & Grease mg/L	Total Phosphorus (as P) mg/L	Total Nitrogen (as N) mg/L	
			Limit: 2	Limit: 10	Limit: 200	Limit: 6.5-8.5	Limit: 15	Limit: 2	Limit: 0.3	Limit:10	
13.01.16	20.01.16	28.01.16	1.0	2	500	7.89	10	<1	0.29	3.44	Some UV lamps defective, High summer temperature
25.02.16	07.03.16	07.03.16	0.4	<2	166	8.22	10	<1	0.29	4.12	
17.03.16	29.03.16	30.03.16	0.4	<2	92	7.96	9	<1	0.44	4.30	
27.04.16	05.05.16	06.05.16	0.5	4	4	7.96	14	<1	0.49	5.69	
26.05.16	10.06.16	14.06.16	0.5	<2	<2	7.60	12	<1	0.15	5.21	
22.06.16	06.07.16	06.07.16	2.6	<2	<1	7.08	13	<1	0.13	7.62	
14.07.16	22.07.16	25.07.16	16.6	<2	<1	7.63	13	<1	0.04	18.8	Cause of high ammonia and nitrogen being investigated
11.08.16	24.08.16	25.08.16	19.8	<2	<1	7.44	12	<1	0.09	23.2	
08.09.16	19.09.16	20.09.16	17.2	2	<1	7.39	21	<1	0.19	19.3	Cause of high ammonia and total nitrogen being investigated and measures implemented to reduce them
12.10.16	18.10.16	19.10.16	10.6	4	<2	7.43	14	<1	0.15	13.9	
17.11.16	28.11.16	29.11.16	0.7	4	<2	7.81	16	<1	0.24	3.04	
07.12.16	13.12.16	14.12.16	0.7	4	<1	7.51	10	<1	0.17	2.85	
12.01.17	18.01.17	19.01.17	0.5	<2	<1	7.62	11	<1	0.16	3.52	
09.02.17	16.02.17	17.02.17	0.4	3	20	7.63	12	<1	0.10	3.67	
09.03.17	20.03.17	22.03.17	0.6	<2	10	7.80	7	<1	0.08	4.83	
06.04.17	20.04.17	26.04.17	0.6	<2	<2	7.81	11	<1	0.09	3.50	
04.05.17	11.05.17	12.05.17	0.6	<2	<2	7.70	20	<1	0.17	5.00	
19.06.17	27.06.17	28.06.17	0.3	<2	<1	7.77	15	<1	0.10	3.50	
20.07.17	28.07.17	31.07.17	0.8	3	<1	7.68	15	<1	0.16	4.13	
24.08.17	31.08.17	01.09.17	0.2	4	<2	7.76	19	<1	0.20	3.11	
12.09.17	20.09.17	21.07.17	0.7	4	<1	7.66	24	<1	0.23	4.07	
12.10.17	20.10.17	24.10.17	0.9	2	<2	7.85	20	<1	0.29	3.15	
16.11.17	24.11.17	27.10.17	1.2	2	<2	7.85	14	<1	0.12	3.52	

Environmental Protection Licence EPL 1730

Yass Valley Council, PO Box 6, Yass, NSW 2582

Yass Sewage Treatment Plant, Faulder Avenue, YASS, NSW 2582

Link to Public Register: <https://www.epa.nsw.gov.au/licensing-and-regulation/public-registers/about-prpoeo>

Yass Sewage Treatment Plant Effluent Quality Data since 2012

EPA Sampling Point: 10 (refer site map for Location)			Monitoring Frequency : Monthly								Comment
Date Sampled	Date Results Obtained	Date Results Published	Pollutant								
			Ammonia (as N) mg/L	BOD ₅ mg/L	Faecal Coliform CFU/100mL	pH	Suspended Solids mg/L	Total Oil & Grease mg/L	Total Phosphorus (as P) mg/L	Total Nitrogen (as N) mg/L	
Limit: 2	Limit: 10	Limit: 200	Limit: 6.5-8.5	Limit: 15	Limit: 2	Limit: 0.3	Limit:10				
13.12.17	19.12.17	21.12.17	0.5	4	1	7.70	11	<1	0.12	3.62	
10.01.18	22.01.18	23.01.18	0.6	4	<2	7.61	15	<1	0.18	4.47	
08.02.18	19.02.18	20.02.18	0.5	5	<2	7.46	14	<1	0.12	3.23	
08.03.18	21.03.18	22.03.18	0.7	4	<2	7.74	15	<1	0.06	4.56	
12.04.18	21.04.18	01.05.18	0.7	<2	<1	7.52	11	<1	0.14	4.22	
29.05.18	06.06.18	07.06.18	1.0	2	<2	7.71	14	<1	0.33	4.47	
14.06.18	21.06.18	22.06.18	0.4	<2	<2	7.78	13	<1	0.21	5.01	
12.07.18	20.07.18	23.07.18	0.3	<2	<2	7.66	29	<1	0.27	9.8	
06.08.18	23.08.18	27.08.18	0.5	<2	<2	7.50	22	<1	0.24	10.4	Cause of high SS and T-N are being investigated and measures are being implemented.
06.09.18	14.09.18	17.09.18	0.3	<2	<2	7.74	16	<1	0.15	5.39	
04.10.18	18.10.18	22.10.18	<0.1	<2	2	7.82	15	<1	0.14	4.6	
08.11.18	23.11.18	26.11.18	0.8	<2	5	7.63	18	<1	0.20	7.15	
06.12.18	18.12.18	20.12.18	0.3	<2	<1	7.79	12	<1	0.09	3.43	
03.01.19	16.01.19	17.01.19	0.4	<2	2	7.55	8	<1	0.04	4.09	
07.02.19	20.02.19	21.02.19	0.4	<2	34	7.70	6	<1	0.06	4.35	
28.03.19	12.04.19	12.04.19	0.2	2	<2	7.54	15	<1	1.96	5.68	High T-P is an anomaly and is being investigated
09.04.19	02.05.19	14.05.19	0.4	<2	82	7.55	19	<1	2.99	5.42	High T-P is an anomaly and is being investigated
09.05.19	23.05.19	30.05.19	0.5	3	<1	7.15	10	<1	0.16	8.89	
06.06.19	21.06.19	25.06.19	0.3	<2	<1	7.16	11	<1	0.19	4.97	
11.07.19	25.07.19	12.08.19	<0.1	2	<2	7.23	16	<1	0.15	4.63	

Environmental Protection Licence EPL 1730

Yass Valley Council, PO Box 6, Yass, NSW 2582

Yass Sewage Treatment Plant, Faulder Avenue, YASS, NSW 2582

Link to Public Register: <https://www.epa.nsw.gov.au/licensing-and-regulation/public-registers/about-prpoeo>

Yass Sewage Treatment Plant Effluent Quality Data since 2012

EPA Sampling Point: 10 (refer site map for Location)			Monitoring Frequency : Monthly								Comment
Date Sampled	Date Results Obtained	Date Results Published	Pollutant								
			Ammonia (as N) mg/L Limit: 2	BOD ₅ mg/L Limit: 10	Faecal Coliform CFU/100mL Limit: 200	pH Limit: 6.5-8.5	Suspended Solids mg/L Limit: 15	Total Oil & Grease mg/L Limit: 2	Total Phosphorus (as P) mg/L Limit: 0.3	Total Nitrogen (as N) mg/L Limit:10	
07.08.19	17.08.19	20.08.19	2.6	<2	<2	7.26	17	<1	0.20	7.28	High Ammonia is being investigated. Higher suspended solids are due to algal matter during drought-like conditions
04.09.19	13.09.19	17.09.19	2.2	<2	<1	7.50	12	<1	0.07	5.45	High Ammonia is being investigated
02.10.19	11.10.19	14.10.19	1.5	2	<1	7.15	16	<1	0.15	4.86	Higher suspended solids are due to algal matter during drought-like conditions
13.11.19	22.11.19	26.11.19	1.4	2	<2	7.84	11	<1	0.08	4.18	
03.12.19	16.12.19	19.12.19	1.3	2	<1	7.52	11	<1	0.08	4.64	
09.01.20	24.01.20	30.01.20	0.3	<2	2	7.73	20	<1	0.19	3.12	Higher suspended solids are due to algal matter during drought-like conditions
13.02.20	26.02.20	27.03.20	0.3	<2	<1	7.31	13	<1	0.11	4.14	
11.03.20	24.03.20	27.03.20	0.3	<2	<1	7.68	5	<1	0.09	4.27	
15.04.20	29.04.20	30.04.20	0.5	<2	<1	7.48	13	<1	0.06	4.49	
14.05.20	25.05.20	25.05.20	0.3	<2	2	7.49	17	<1	0.10	4.29	Sloughing-off from Catch Balance Pond caused higher SS
10.06.20	18.06.20	23.06.20	0.4	3	<1	7.46	15	<1	0.10	3.99	
09.07.20	20.07.20	21.07.20	1.0	<2	<1	7.45	16	<1	0.12	4.02	Sloughing-off from Catch Balance Pond caused higher SS